

Providing and
Protecting
Kenosha's
Greatest
Natural
Resource

Curtis Czarnecki
General Manager
Kenosha water Utility



Presentation Overview

- Kenosha Water Utility Overview
- Drinking Water Treatment Process
- Drinking Water Storage and Distribution
- Questions?
- Additional Water Topics (Time Permitting):
 - Lead Service Line Replacement Program
 - Great Lakes Compact

Kenosha's Water History


- 1876 – The Park City Water Company became the first organized public water works in the City of Kenosha
- 1880 – The North Side Water Works was organized and authorized to construct mains and operate a system in the territory north of Pike Creek
- 1895 – Common Council passed an ordinance granting the City of Kenosha the right to purchase the water systems owned by the Park City Water Company and the North Side Water Company

Water System Purchase


- Purchase Price \$137,000
 - \$20,000 for the artesian well system
 - \$117,000 for the lake intake system on south side of harbor
- System Components
 - Two pumping engines (capacity of two million gallons per day each)
 - Two boilers (125 horsepower each)
 - 13 miles of cast iron water main
 - 105 fire hydrants
 - 4,000,000 gallon per day pumping station
 - 24" Lake Michigan intake pipe

Operational Oversight


- September 4, 1895
 - Ordinance No. 172 was adopted by the Common Council creating the Board of Water Commissioners
- Board of Water Commissioners Responsibilities
 - Rules
 - Regulations
 - Rates




View of Kenosha - 1881



Water Plant located on the south side of the harbor provided 4 million gallons per day - 1895




Installation of 24" Intake Water Pipe into Lake Michigan - South Side of Harbor - 1895




Construction of Original Water Plant (north side of harbor) - 1916



Installation of 42" Cast Iron Intake Pipe into Lake Michigan - 1916



Completed Pumping Station - 1918



First Addition to Filter Plant 6 MGD, Bottom Level - 1929



New 20 MGD Filtration Plant - 1964

Kenosha Water Utility

O. Fred Nelson Water Production Plant



Production Plant Capacity

- Approved Withdrawal
 - 35.68 Million Gallons Per Day (Annual Average)
- Sand Filtration
 - 20 Million Gallons Per Day
 - Four Filters all rated at 5 Million Gallons Per Day Each
- Membrane Filtration
 - Summer Conditions – 21.775 Million Gallons Per Day
 - Winter Conditions – 15.575 Million Gallons Per Day

The Source of Kenosha's Drinking Water





Intake Wet Well, Low Lift Pumping



Raw Water Turbidity



10/31/2014



Adding Alum & Chlorine/Flash Mixer



Aluminum Sulfate Storage & Day Tank



Top of 2.5MG Settling Basin

Slow Mixer Chains



Slow Mix Paddles



Settling Basin Cleaning







Sand Filter Gallery

Sand Filters

4 @ 5MGD Each





Sand Filter Effluent & Turbidimeter



A photograph of a sand filter control valve assembly. The main component is a large, light blue cylindrical tank. Attached to the side is a grey motorized valve actuator with a pressure gauge. Below it is a smaller grey valve. To the right, a complex network of pipes and smaller valves is visible, including two yellow pressure gauges and several blue-handled manual valves. The background is a concrete wall.

Sand Filter Control Valve

Sand Filtration Questions?





Strainers For Membrane Filtration



**Continuous Micro-Filtration
(CMF) Gallery**



25 CMF Units

Filter Modules

90 or 108 Per Unit




Filter Module Cutaway



Clean-In-Place (CIP) Chemicals









Microfiltration and Ultrafiltration Info.

- Microfiltration
 - Membrane Pore Size
 - 0.2 microns (μm)
 - Removes suspended solids and bacteria
 - E. Coli, Cryptosporidium, Giardia
- Ultrafiltration
 - Pore Size 0.04 microns (μm)
 - Removes suspended solids, bacteria and viruses



THE RELATIVE SIZE OF PARTICLES

From the COVID-19 pandemic to the U.S. West Coast wildfires, some of the biggest threats now are also the most microscopic.

A particle needs to be 10 microns (μm) or less before it can be inhaled into your respiratory tract. But just how small are these specks?

Here's a look at the relative sizes of some familiar particles >

HUMAN HAIR 50-180 μm >
FOR SCALE

FINE BEACH SAND 90 μm >

GRAIN OF SALT 60 μm >

WHITE BLOOD CELL 25 μm >

GRAIN OF POLLEN 15 μm >

DUST PARTICLE (PM₁₀) <10 μm >

RED BLOOD CELL 7-8 μm >

RESPIRATORY DROPLETS 5-10 μm >

DUST PARTICLE (PM_{2.5}) 2.5 μm >

BACTERIUM 1-3 μm >

WILDFIRE SMOKE 0.4-0.7 μm >

CORONAVIRUS 0.1-0.5 μm >

T4 BACTERIOPHAGE 0.225 μm >

ZIKA VIRUS 0.045 μm >



Pollen can trigger allergic reactions and hay fever—which 1 in 5 Americans experience every year.

Source: Harvard Health

The visibility limits for what the naked eye can see hovers around 10-40 μm .



Respiratory droplets have the potential to carry smaller particles within them, such as dust or coronavirus.



Wildfire smoke can persist in the air for several days, and even months.

Membrane Filtration Questions?





Chemical Addition Vault

Chlorine Room





Chlorine Gas One-Ton Cylinders

Corrosion Control (Ortho-Phosphate)



Hydrofluosilicic Acid (Fluoride)



Contact Tank/Finished Water Reservoir



High-Lift Pumping 6 @ 10 MGD



Surge Tank Room



“Out-the-Door”



Generators

2.0 MW Capacity








Main Electric Room



Backwash Tank
0.25MG




Control Room






Air Compressors

The Lab



Bacteria Testing




Water Treatment Questions?



Water Distribution and Storage

- Water Distribution
 - 370 Miles of Water Main ranging in size from 4" – 48"
 - 30,500 Water Services
 - 3,400 Fire Hydrants
 - 6,100 Valves
- Water Storage
 - 6 Elevated Water Towers (Including Washwater Tank)
 - 4 Ground Storage Reservoirs
 - 5 Booster Stations



- Legend**
- Water Tank
 - Water Main
 - Sanitary Main
 - Kenosha County Boundary
 - Kenosha
 - Bristol
 - Pleasant Prairie
 - Somers
 - Somers (T)
 - Parks

0 600 1,200 ft

Distribution Network Maintenance

- Emergency Maintenance
 - Water Main Breaks
 - Water Service Repair/Replace
 - Broken Valves
 - Frozen Water Services
 - Inoperable Fire Hydrants
- Preventative Maintenance
 - Fire Hydrant Flushing
 - Valve Exercising
 - Meter Replacement
 - Leak Detection

Water Distribution System

- Distribution Network is divided into three pressure zones
 - Zone 1 – All pressure and volume is supplied exclusively by the water production plant
 - Generally located east of 39th Avenue
 - Zone 2 – Contains four ground storage reservoirs, two elevated water towers and three booster stations to provide required pressure and volume
 - Generally located between 88th and 39th Avenues
 - Zone 3 – Contains three elevated water towers and two booster stations to provide required pressure and volume
 - Located west of 88th Avenue

Elevated Water Tower

- Provides pressure to network
 - 1 psi for every 2.31-ft of elevation
- Provides volume for customer demand
 - Smallest Tank 150,000 gallons
 - Largest Tank 750,000 gallons





Ground Storage Reservoir





B
O
O
S
T
E
R

S
T
A
T
I
O
N



Water Customers

- Total of 31,800 customer accounts
- Retail Customers:
 - Residential
 - Multi-family Residential
 - Commercial
 - Industrial
 - Public Authority
- Wholesale Customers:
 - Village of Pleasant Prairie
 - Village of Somers
 - Village of Bristol

Lead Service Line Replacement Program


- Nearly 1/3 of Kenosha Water Utility water services have the potential to be constructed of lead.
- Local ordinance prohibited lead from being installed for water services after 1937.
- Historically, public water utility's in Wisconsin were prohibited from providing financial assistance to property owners for private lead service line replacement.
- In 2018 the Wisconsin Legislature enacted Wisconsin Act 137 allowing public water utility's to provide financial assistance to property owners using customer rates

Lead Service Line Replacement Program

- Kenosha was first Utility to seek approval from the PSC under the provision of Wisconsin Act 137
- Docket Number 2820-LS-100
- Required enactment of local ordinance per Wis. Stat. 196.372(2)(a)
- Financial assistance may only be provided if partial lead service line replacement is avoided per Wis. Stat. 196.372(2)(b)
- Financial Assistance defined as 100% of customers costs
 - Grant for 50% of cost up to a maximum of \$2,000
 - Loan for remaining balance paid over a ten year period as a special charge on their tax bill
- Cost to be recovered through rates and request for deferral of costs
- KWU required to file a rate application no later than two years from the effective date of the final commission decision

**Private Property
Owner's Responsibility**

**Municipality's
Responsibility**



PROPERTY LINE

CURB STOP

WATER
METER

WATER SERVICE LINE

WATER
MAIN



1

1) Lead



2

2) Iron



3

3) Copper




4

4) Black Poly/Alkathene



-  Potential Lead Service
-  Non Lead Service
-  City of Kenosha
-  Bristol
-  Paris
-  Pleasant Prairie
-  Somers
-  Somers (T)
-  Lake Michigan



Lead Service Line Replacement Program


- Formal program was enacted in 2018
- Kenosha used rates to provide a 50% grant to property owners as authorized by the Public Service Commission
- In 2021 the Wisconsin Department of Natural Resources (WDNR) offered a principal forgiveness loan to municipalities through the Safe Drinking Water Loan Program (SDWLP)
 - Kenosha was awarded \$1.95 million under the 2021 program
- Kenosha has applied for SDWLP funding in the amount of \$2.4 million for 2022

Great Lakes Compact

- Became effective on December 8, 2008
- Formal agreement between US states and Canadian provinces that border the Great Lakes which details how they will work together to manage and protect the watershed collectively
- Compact bans the diversion of Great Lakes water with limited exceptions
- Exceptions include
 - Straddling communities
 - Community in a straddling county



Wisconsin has 3 major basins





subcontinental divide

The Southeastern
Wisconsin Regional
Planning Commission
(SEWRPC) area

Questions

Curt Czarnecki

Kenosha Water Utility

262-653-4306

cczarnecki@Kenosha.org

